

[OBIX-187] Redirects (7) Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |
| Fix Version/s: | None |

| | | | |
|---------------------|----------------|------------------|-------------|
| Type: | Bug | Priority: | Minor |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

| | |
|--------------------|---|
| Resolution: | I don't see any problem here. I think it is better to use the non-https links by default. Further, http://www.unc.edu/ seems to be the more official URL. If the request is redirected later by the organization it is not really a problem. |
|--------------------|---|

Description

"The link checker at: <http://validator.w3.org/checklink>, reports seven (7) redirects in the current draft.

Line: 911 <http://www.oasis-open.org/> redirected to <https://www.oasis-open.org/>

Status: 301 -> 200 OK

warning Lines: 739, 819 <http://www.oasis-open.org/committees/obix/> redirected to <https://www.oasis-open.org/committees/obix/>

Status: 301 -> 200 OK

warning Line: 816 http://www.oasis-open.org/committees/comments/index.php?wg_abbrev=obix redirected to https://www.oasis-open.org/committees/comments/index.php?wg_abbrev=obix

Status: 301 -> 200 OK

warning Line: 916 <http://www.oasis-open.org/policies-guidelines/trademark> redirected to <https://www.oasis-open.org/policies-guidelines/trademark>

Status: 301 -> 200 OK

warning Line: 825 <http://www.oasis-open.org/committees/obix/ipr.php> redirected to <https://www.oasis-open.org/committees/obix/ipr.php>

Status: 301 -> 200 OK

warning Line: 746 <http://www.unc.edu/> redirected to <http://unc.edu/>

Status: 301 -> 200 OK

warning Line: 855 <http://www.oasis-open.org/policies-guidelines/ipr> redirected to <https://www.oasis-open.org/policies-guidelines/ipr>

Status: 301 -> 200 OK

"

Comments

Comment by [Markus Jung](#) [05/Mar/14]

I don't see any problem here. I think it is better to use the non-https links by default.

Further, <http://www.unc.edu/> seems to be the more official URL. If the request is redirected later by the organization it is not really a problem.

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-128] 1.2 Normative References Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |
| Fix Version/s: | None |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Minor |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

Resolution: Changed reference. Fixed in WD10

Description

"1.2 Normative References reads in part:

SOAP M Gudgin, M Hadley, N Mendelsohn, J Moreau, H Nielsen, A Karmarkar, Y Lafon, W3C SOAP Version 1.2 (Second Edition), W3C Recommendation 27 April 2007

SOAP is a multi-part standard and the citation given isn't clear if all or part of the SOAP standard is being cited as a normative reference.

The correct citation for SOAP Version 1.2 Part 0: (Second Edition) reads:

SOAP12-PART0

SOAP Version 1.2 Part 0: Primer (Second Edition) , N. Mitra, Y. Lafon, Editors, W3C Recommendation, 27 April 2007, <http://www.w3.org/TR/2007/REC-soap12-part0-20070427/> . Latest version available at <http://www.w3.org/TR/soap12-part0/> .

As per the W3C bibliography generator: <http://www.w3.org/2002/01/tr-automation/tr-biblio-ui>"

Comments

Comment by [Markus Jung](#) [05/Mar/14]

Changed reference. Fixed in WD10

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-127] 1.3 Normative References - delete its empty Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |

| | |
|-----------------------|------|
| Fix Version/s: | None |
|-----------------------|------|

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Minor |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

| | |
|--------------------|--|
| Resolution: | Removed non-normative references section. Fixed in WD 10. |
|--------------------|--|

Description

| |
|---------------------------------------|
| 1.3 Non-Normative References is empty |
|---------------------------------------|

Comments

| |
|---|
| Comment by Markus Jung [05/Mar/14] |
| Removed non-normative references section. |
| Comment by Markus Jung [05/Mar/14] |
| Fixed in WD 10. |
| Comment by Toby Considine [30/Jun/15] |
| Closed with WD44 prior to reporting for CSD04 |
| |

| | |
|---|--|
| [OBIX-126] 1.2 Normative References - SOAP not cited Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 11/Nov/14 | |
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |
| Fix Version/s: | None |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Applied | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

Description

| |
|---|
| "After a close reading of the text, it appears that there are no normative references invoking any part or section of the SOAP standards group. Therefore, whatever was meant by the citation is irrelevant since it isn't used in the document. Delete the SOAP reference and/or repair the text to cite some portion of the SOAP specifications normatively." |
|---|

Comments

| |
|--|
| Comment by Markus Jung [05/Mar/14] |
| There is a normative reference to SOAP. SOAP SOAP Version 1.2 Part 0: Primer (Second Edition) , N. Mitra, Y. Lafon, Editors, W3C Recommendation, 27 April 2007, http://www.w3.org/TR/2007/REC-soap12-part0-20070427/ . Latest version available at http://www.w3.org/TR/soap12-part0/ |

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-125] 3. Conformance - violates TC process Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |
| Fix Version/s: | None |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

Resolution: The new conformance section is now reformatted to use a numbered list.

Description

"3. Conformance reads:

An implementation is compliant with this specification if it implements all MUST or REQUIRED level requirements.

The TC Process requires:

8(a) - must include a separate section, listing a set of numbered conformance clauses, to which any implementation of the specification must adhere in order to claim conformance to the specification (or any optional portion thereof).

There are no numbered clauses nor is there any accounting for interaction of clients and servers that follow ""SHOULD"" statements in this draft.

"

Comments

Comment by [Markus Jung](#) [05/Mar/14]

The new conformance section is now reformatted to use a numbered list.

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-124] 3. Conformance - null and void Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |

| | |
|-----------------------|------|
| Fix Version/s: | None |
|-----------------------|------|

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

| | |
|--------------------|--|
| Resolution: | <p>Removed the statement and changed it to:</p> <p>"To be compliant with this specification an OBIX server MUST provide an SOAP interface accoding to the WSDL document that is provided as additional artifact to this specification. An OBIX client that uses SOAP to interact with the server MUST use the SOAP message definition according to the types defined in the WSDL file and the referenced OBIX core schema."</p> <p>Fixed in WD10</p> |
|--------------------|--|

Description

| |
|---|
| <p>"3. Conformance reads:</p> <p>*****</p> <p>An implementation is compliant with this specification if it implements all MUST or REQUIRED level requirements.</p> <p>*****</p> <p>There are no, repeat no, MUST or REQUIRED level requirements in this draft. Not even one.</p> <p>"</p> |
|---|

Comments

| |
|--|
| <p>Comment by Markus Jung [05/Mar/14]</p> <p>Removed the statement and changed it to:</p> <p>"To be compliant with this specification an OBIX server MUST provide an SOAP interface accoding to the WSDL document that is provided as additional artifact to this specification. An OBIX client that uses SOAP to interact with the server MUST use the SOAP message definition according to the types defined in the WSDL file and the referenced OBIX core schema."</p> <p>Fixed in WD10</p> |
| <p>Comment by Toby Considine [30/Jun/15]</p> <p>Closed with WD44 prior to reporting for CSD04</p> |
| <p></p> |

| | | | |
|---|--|--|--|
| [OBIX-123] WSDL schema error Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14 | | | |
| Status: | Closed | | |
| Project: | OASIS Open Building Information Exchange (oBIX) TC | | |
| Component/s: | SOAP Specification | | |
| Affects Version/s: | SOAP PR02 | | |
| Fix Version/s: | None | | |

| | | | |
|--------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |

| | |
|---------------------|------------|
| Environment: | TAB Review |
|---------------------|------------|

Description

"The file name of the WSDL file is obix-soap-v1.wsdl.

The schema document reports:

```
schemaLocation=""./obix.xsd
```

Attempts to validate the WSDL file with a 404 on the schema location.

All separate computer files are required to be valid by the TC process.

"

Comments

| |
|---|
| Comment by Markus Jung [03/Mar/14] |
| The name of the file is obix-v1.1.xsd. I changed it now. The given wsdl assumes that the schema resides in the same relative directory. |
| Comment by Markus Jung [05/Mar/14] |
| The schemaLocation is removed from the example given in the specification and changed in the .wsdl file. |
| Comment by Markus Jung [06/Nov/14] |
| The name of the file is obix-v1.1.xsd. I changed it now. The given wsdl assumes that the schema resides in the same relative directory. |
| The schemaLocation is removed from the example given in the specification and changed in the .wsdl file. |
| Comment by Toby Considine [30/Jun/15] |
| Closed with WD44 prior to reporting for CSD04 |
| |

[OBIX-122] WSDL schema error - cannot resolve obix:obj Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |
| Fix Version/s: | None |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

| | |
|--------------------|--|
| Resolution: | I think the problem here was that there were slightly different namespace definitions used in the .wsdl and .xsd file for the public review. In the next WD artifacts of the files the problem will be resolved. |
|--------------------|--|

Description

"After doing an ad-hoc correction of the file name, attempts to validate the WSDL schema resulted in this error:

```
*****
```

Description: Could not solve name 'obj' from namespace {<http://docs.oasis-open.org/obix/schema/1.1>} to a defined schema element.

```
*****
```

Since the first global element in obix-v1.1.xsd is ""obj"", this is a path error but I did not run it to ground."

Comments

Comment by [Markus Jung](#) [05/Mar/14]

I think the problem here was that there were slightly different namespace definitions used in the .wsdl and .xsd file for the public review. In the next WD artifacts of the files the problem will be resolved.

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-108] Hanging paragraphs (2 cases) Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 17/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |
| Fix Version/s: | None |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Minor |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

Description

"There are several hanging paragraphs, that is where a header occurs followed immediately by content. Which means if I cite ""2 Soap Binding"", do I mean all of chapter 2 or do I just mean the text that immediately follows that heading?"

There are two (2) hanging paragraphs in this draft."

Comments

Comment by [Markus Jung](#) [05/Mar/14]

I don't see the issue. Line numbers would be nice to reference exactly the problem.

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-102] Normative vs. non-normative text? Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | SOAP PR02 |
| Fix Version/s: | None |

| | | | |
|--------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |

| | |
|---------------------|---|
| Labels: | None |
| Environment: | TAB Review |
| Resolution: | Added a statement in the introduction of the document, that the given examples in the spec are non-normative but the referenced additional artifacts acts as a normative guide for an implementation. |

Description

"This draft contains no statement to guide the reader in distinguishing normative from non-normative text.

Are the examples in 2.1 Example normative?

What is or is not an example in 2.5 WSDL and what of any of that section is normative?"

Comments

Comment by [Markus Jung](#) [06/Mar/14]

Added a statement in the introduction of the document, that the given examples in the spec are non-normative but the referenced additional artifacts acts as a normative guide for an implementation.

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-88] Conformance clause inadequate in SOAP binding Created: 20/Feb/14 Updated: 30/Jun/15 Resolved: 06/Nov/14

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | OBIX 1.1 XSD PR02 |
| Fix Version/s: | SOAP PR02 |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Improvement | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | TAB Review | | |

| | |
|--------------------|---|
| Resolution: | See related JIRA issue. Conformance clause is updated in WD 10. |
|--------------------|---|

Description

Because this is a separate specification on its own a detailed conformance clause is needed.

But this will not do:

"An implementation is compliant with this specification if it implements all MUST or REQUIRED level requirements."

1. "implementation" is not defined or characterized. Server? Request? both?
2. A reference to where are these MUST and REQUIRED found is needed, even if high level.

Comments

Comment by [Markus Jung](#) [05/Mar/14]

See related JIRA issue. Conformance clause is updated in WD 10.

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-56] Editorial: Tables and Figures need to be identified, have separate tables of... in the front matter Created: 12/Sep/13 Updated: 30/Jun/15

Resolved: 16/Dec/13

| | |
|---------------------------|---|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | ENCODINGS Specification, OBIX 1.1 Specification, REST Specification, SOAP Specification |
| Affects Version/s: | oBIX 1.1 PR01, SOAP PR01, ENCODINGS PR01, REST PR01 |
| Fix Version/s: | None |

| | | | |
|---------------------|------------------------|------------------|-------------|
| Type: | Bug | Priority: | Major |
| Reporter: | William Cox (Inactive) | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | William Cox | | |

| | |
|--------------------|--|
| Resolution: | Number the tables and figures. Create a table of figures and table of tables (!) after the Table of Contents for each specification. |
|--------------------|--|

Description

See e.g. OBIX 1.1 PR01, starting at lines 270, 1522, 1890. Tables should have a numbered caption via insert caption; figures likewise. Suggest sequential numbering through the document.

Comments

| |
|---|
| Comment by Craig Gemmill [27/Sep/13] |
| For the 1.1 spec, this is a duplicate of OBIX-34 . So I'll work the 1.1 core spec there. |
| Noted that reporter here suggests sequential numbering. In OBIX-34 , the suggestion is (per other recent specs) <chapter>-<number> for both Figures and Tables. Plan is to go with the latter approach for consistency. |
| Comment by Markus Jung [02/Oct/13] |
| Fixed for ENCODINGS in OBIX-Encodings-v1.0-wd07. |
| Comment by Craig Gemmill [16/Oct/13] |
| Fixed for core spec in WD16. |
| Comment by Markus Jung [07/Nov/13] |
| In the SOAP binding document are no figures and no tables. |
| Comment by Markus Jung [07/Nov/13] |
| Table of Tables added to the Encodings document WD 08. |
| Comment by Toby Considine [30/Jun/15] |
| Closed with WD44 prior to reporting for CSD04 |
| |

[OBIX-55] Localization Created: 09/Sep/13 Updated: 30/Jun/15 Resolved: 16/Dec/13

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | oBIX 1.1 PR01 |
| Fix Version/s: | None |

| | | | |
|--------------|-------------|------------------|-------|
| Type: | Improvement | Priority: | Major |
|--------------|-------------|------------------|-------|

| | | | |
|---------------------|----------------|------------------|----------------|
| Reporter: | Toby Considine | Assignee: | Toby Considine |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | Toby Considine | | |

Description

We should limit chained references. If the Localization from REST is moved into Encodings or into the core 1.1 (best), Then the SOAP binding would no longer need to make normative references to the REST Binding, which would simplify the document set and conformance.

Comments

| |
|---|
| Comment by Markus Jung [07/Nov/13] |
| I think in this case it could not be avoided, since the localization relies on the HTTP header variable. It would be possible to duplicate the according section from the REST document, but duplicating information is always a bad idea. In this case I would keep the reference. |
| Comment by Toby Considine [30/Jun/15] |
| Closed with WD44 prior to reporting for CSD04 |
| |

[OBIX-54] SOAP: XML Namespaces in examples Created: 09/Sep/13 Updated: 30/Jun/15 Resolved: 16/Dec/13

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | oBIX 1.1 PR01 |
| Fix Version/s: | None |

| | | | |
|---------------------|----------------|------------------|-------------|
| Type: | Bug | Priority: | Minor |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | Toby Considine | | |

| | |
|------------------|--|
| Proposal: | <p>This section should be removed or updated to not mandate possible collisions with other specifications. For example, If at a future date, A system supports oBIX 1.2 with an XML Encoding and a REST Binding, this section would seem to require that SOAP indicate a 1.1 namespace...</p> <p>Alternately, this section should indicate that the examples are non-normative, and use 1.1 for clarity.</p> |
|------------------|--|

Comments

| |
|--|
| Comment by Markus Jung [07/Nov/13] |
| For the WSDL it is important to provide the version within the namespace, so a client can distinguish between different versions. |
| I think this topic should be discussed, how to handle future version releases and how the the bindings and encodings can evolve in an independent way. |
| Comment by Toby Considine [30/Jun/15] |
| Closed with WD44 prior to reporting for CSD04 |
| |

[OBIX-53] SOAP - Namespaces throughout document Created: 09/Sep/13 Updated: 30/Jun/15 Resolved: 16/Dec/13

| | |
|----------------|--------|
| Status: | Closed |
|----------------|--------|

| | |
|---------------------------|--|
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | oBIX 1.1 PR01 |
| Fix Version/s: | None |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | Toby Considine | | |

Description

All examples are inconsistent with the rules on prefixes described Section 2.3 (XML Encoding) of the Common Encodings document. It may be that those rules (in encodings) are incorrect. This bears some group discussion.

Comments

| |
|--|
| Comment by Markus Jung [07/Nov/13] |
| The namespace rules regarding the prefix are modified in the encodings document WD08. Now it should be fine. |
| Comment by Toby Considine [30/Jun/15] |
| Closed with WD44 prior to reporting for CSD04 |
| |

| | |
|---|--|
| [OBIX-52] SOAP: Simple editorial issues <small>Created: 09/Sep/13 Updated: 30/Jun/15 Resolved: 16/Dec/13</small> | |
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | oBIX 1.1 PR01 |
| Fix Version/s: | None |

| | | | |
|---------------------|--------------------------------|------------------|-----------------------------|
| Type: | Improvement | Priority: | Major |
| Reporter: | Toby Considine | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | Toby Considine | | |

Description

| |
|--|
| Update namespaces on title page |
| Remove extra lines between paragraphs |
| Lines 33-35: Update namespaces in example |
| 78-199: If the WSDL is intended to be normative, then it should be placed in a separate artifact. It is OK to include it w/l the document for ease of reading, but if so, it should be noted that the machine readable artifact is normative |

Comments

| |
|--|
| Comment by Markus Jung [07/Nov/13] |
| Fixed in working draft 6: |

-) Namespaces could be changed to:

<http://docs.oasis-open.org/obix/wSDL/1.1>

<http://docs.oasis-open.org/obix/schema/1.1>

Needs a discussion.

-) Extra lines between paragraphs removed

-) WSDL is also provided as separate normative artifact and listed within the additional artifacts section

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04

[OBIX-29] Code example format Created: 05/Sep/13 Updated: 30/Jun/15 Resolved: 13/Dec/13

| | |
|---------------------------|--|
| Status: | Closed |
| Project: | OASIS Open Building Information Exchange (oBIX) TC |
| Component/s: | SOAP Specification |
| Affects Version/s: | oBIX 1.1 PR01 |
| Fix Version/s: | SOAP WD06 |

| | | | |
|---------------------|-----------------------------|------------------|-----------------------------|
| Type: | Bug | Priority: | Major |
| Reporter: | Markus Jung | Assignee: | Markus Jung |
| Resolution: | Fixed | | |
| Labels: | None | | |
| Environment: | Markus Jung | | |

Description

SOAP binding document - line 37:
Formatting should be changed to code example.

Comments

Comment by [Markus Jung](#) [07/Nov/13]

Fixed in WD06

Comment by [Toby Considine](#) [30/Jun/15]

Closed with WD44 prior to reporting for CSD04